

Anzahl Wohnungen	Leistungsbedarf (S_{eff}) mit elektrischer Warmwasserbereitung in kVA	Strom in Ampere	Hausanschluss Absicherung	Leistungsbedarf (S_{eff}) ohne elektrischer Warmwasserbereitung in kVA	Strom in Ampere	Hausanschluss Absicherung
1	34	49	63	14,5	21	63
2	52	75	"	24	35	"
3	64	92	80	32	46	"
4	73	105	100	37	53	"
5	81	117	125	41	59	"
6	87	126	"	44	64	"
7	93	134	160	47	68	80
8	98	141	"	50	72	"
9	103	149	"	53	76	"
10	107	154	"	55	79	"
11	110	159	"	57	82	"
12	113	163	"	59	85	"
13	116	167	200	61	89	100
14	119	172	"	63	91	"
15	122	176	"	65	94	"
16	125	180	"	67	97	"
17	128	185	"	69	100	"
18	130	188	"	70	101	"
19	132	191	"	71	102	"
20	134	193	"	72	104	"
22	138	199	"	74	107	"
24	142	205	"	76	110	125
26	146	211	224	78	113	"
28	150	217	"	80	115	"
30	153	221	"	82	118	"
32	156	225	"	84	121	"
34	159	229	"	86	124	"
36	161	232	250	87	126	"
38	163	235	"	88	127	"
40	165	238	"	89	128	"
45	170	245	"	92	133	160
50	175	253	"	95	137	"
55	179	258	260	97	140	"
60	183	264	"	99	143	"
65	186	268	300	101	146	"
70	189	273	"	102	147	"
80	195	281	"	104	150	"
90	200	289	"	106	153	"
100	205	296	"	108	156	"